



SUN VALLEY ELECTRIC MFG., INC.
1334 N. 21 ST. AVE. PHX. AZ. 85009
 602-258-6448 FAX# 602-254-6923

*U.L. LISTED DEADFRONT SWITCHBOARD E84151
 *NEMA 3R RATED UNLESS NOTED OTHERWISE
 *ALUMINUM BUS WITH ALSTAN 80 PLATING
 *ANSI 61 LIGHT GREY POWDER COATED FINISH

JOB ADDRESS: -

DATE:

CONTRACTOR:

DISTRIBUTOR:

P.O. NUMBER:



SVE S.O. #:

VOLTAGE: 240/120V DELTA 3PH/4W 400AMP

UTILITY:

AIC: 100KAIC

underground pull sections may be field installed either left or right



SOCKETS

7

EUSERC 306

TEST BLOCKS

EUSERC

311

SOCKETS

7

EUSERC 306

TEST BLOCKS

EUSERC

311

200 200

3 3

T-FUSIBLE PULLOUT SWITCHES

SVUG400-13

SYSTEM-22-13

PAD MOUNT UNDERGROUND FEED